September 2022





UNIVERSITY of NORTH ALABAMA

Police Department Activity Log

September 2022

Nature (classification)	Case Number	Date/Time Occurred	Date/Time Reported	General Location	Disposition
Possession of Marijuana	220900136	9-1-22 2325 mt		Rivers Hall	Refer to Judical x2
Car Burglary Theft of Property	220900536	9-5-22 1200 mt		Parking Deck	Open Case
Harassing Communications	220900651	9-2-22 0300 mt	9-6-22 0800 mt	Harrison Plaza	Open Case
Possession of Marijuana	220900843	9-8-22 1245 mt		Mattielou Hall	Refer to Judicial
Theft of Property	220901030	9-2-22	9-8-22 0830 mt	Harrison Plaza	Open Case
Leaving Scene of an Accident	220901250	9-11-22 1130 mt		Lions Gate Apts	Open Case
Car Burglary	220901390	9-11-22 1330 mt	9-12-22 0948 mt	Parking Deck	Open Case
Theft of Property	220901634	9-14-22 1030 mt		Rivers Hall	Open Case
Underage Drinking	220902140	9-18-22 0125 mt		Rivers Hall	Refer to Judical

September 2022

Possession of Drugs	2209002356	9-21-22 0017 mt	Cypress St	Cleared by Adult Arrest
Harassing Communications	220903067	9-26-22 1000 mt	Twin Oaks	Open Case
Fire Alarm	220900073	9-1-22 1530 mt	Olive Hall	Burnt Food in Microwave
Fire Alarm	220900088	9-1-22 1657 mt	Appleby West	Heat from Cook Top
Fire Alarm	220900142	9-2-22 0027 mt	Olive Hall	Perfume in Air
Fire Alarm	220900392	9-4-22 0245 mt	Rice Hall	Unknown Cause
Fire Alarm	220901008	9-9-22 1019 mt	Appleby West	Air Freshener in Room
Fire Alarm	220901441	9-12-22 2336 mt	Olive Hall	Cooking in Room
Fire Alarm	220901675	9-14-22 1421 mt	Appleby West	Cooking in Room
Fire Alarm	220901693	9-12-22 0955 mt	GUC	Smoke Hood in Panda Express not Activated before Cooking
Fire Alarm	220902068	9-17-22 1317 mt	Olive Hall	Curling Iron Overheating
Fire Alarm	220902215	9-18-22 2210 mt	Mattielou Hall	Excessive Hair Spray in Room
Fire Alarm	220902460	9-21-22 0224 mt	Olive Hall	Perfume/aerosol in dorm room
Fire Alarm	220902724	9-23-22 1022 mt	Mattielou Hall	Unknown Cause
Fire Alarm	220903171	9-27-22 0629 mt	SET Building	Low Battery in Alarm System
Fire Alarm	220903386	9-28-22 1800 mt	SRC	Faulty Sensors in System
Fire Alarm	220903508	9-30-22 0001 mt	Appleby West	Aerosol Perfume in Room
Fire Alarm	220903596	9-30-22 1831 mt	Olive Hall	Popcorn being cooked in lobby